

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 8110-2044:0004 Page 1 of 1

**CATEGORY:** 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)

**LISTEE:** Tamko Building Products, Inc. 220 West 4th Street, Joplin, MO 64801  
Contact: Aaron Phillips (417) 624-6644 Fax (800) 841-1925  
Email: aaron\_phillips@tamko.com

**DESIGN:** Envision composite decking board \*square and grooved edge, 7/8" thick x 5.5" width. Refer to the manufacturer's installation instructions and product data sheets.

**RATING:** Class C Flame Spread (2010 CBC Section 709A.3 will apply)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee name and UL label.

**APPROVAL:** Listed as decking materials for use in the Wildland Urban Interface areas.

**NOTE:** Test Protocol SFM 12-7A-4A

\*Rev 08-13-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*